

ENVIRONMENT PROTECTION ACT 1970
SECTION 30A APPROVAL

TO: TRUENERGY YALLOURN PTY LTD


OF: EASTERN ROAD, YALLOURN NORTH, VIC 3825

WHEREAS you are the occupier of premises situated at TRUenergy Yallourn Power Station, Eastern Road, Yallourn Vic 3825 ("the premises").

You have applied under Section 30A (2) of the Environment Protection Act 1970 ("the Act") for an Approval under Section 30A of the Act to discharge waste from the premises into the environment;

NOW TAKE NOTICE that the Environment Protection Authority ("the Authority") HEREBY grants its approval to your application under Section 30A subject to the conditions in Attachment A of this approval.

DATED: 14 June 2012


.....
ANTHONY CRAIG ROBINSON
MANAGER, DEVELOPMENT ASSESSMENTS
ENVIRONMENT PROTECTION AUTHORITY

NOTE:

Pursuant to Section 30A(1B) of the Act this Approval has no effect unless the conditions to which it is subject are complied with. If you operate outside any of the conditions of this Approval you may be prosecuted for breach of the Act.

ATTACHMENT A

Conditions:

Operational Requirements:

1. This approval allows the approval holder to discharge wastewater from the premises to the Latrobe River (receiving water) in accordance with TRUenergy Yallourn 30A application finalised on 14 June 2012.
2. This approval will expire at midnight on 12 October 2012.
3. This approval allows a maximum discharge as specified in the application.
4. The wastewater discharge must not cause to exceed the background water quality (99th percentile in Table 2 of the application) of water samples taken from downstream of the discharge point.
5. This approval holder must inform Southern Rural Water, other authorities and property owners likely to be affected by the discharge to the receiving water.

Monitoring Requirements

6. Every week, the approval holder must collect water samples from upstream and downstream of the discharge point and the wastewater being discharged.
7. The approval holder must analyse the water samples for parameters specified in Table 2 of the application.
8. The approval holder must conduct a risk assessment to determine the impacts of discharge to the receiving water.
9. The approval holder must conduct daily visual inspection of the discharge and the receiving water.

Reporting Requirements

10. Fortnightly, the results of analyses must be submitted by the EPA during the duration of this approval.
11. On or before 12 of September 2012, the risk assessment must be submitted to the EPA.
12. The approval holder must immediately notify EPA of any non-compliance with the conditions of this approval.